**504.3 Stair enclosure pressurization increase.** For Group R-1 and R-2 occupancies in buildings of Type VA construction equipped throughout with an approved automatic sprinkler system in accordance with Section 903.3.1.1, the maximum number of stories permitted in Section 504.2 May be increased by one provided the interior exit stairways and ramps are pressurized in

**<u>504.4</u> Roof Structures.** (Numbering change only; remains as printed in 2012 IBC)

accordance with Section 909.20 and Section 909.11.

BLANK